

**5.9.4 1995 Lighting Energy Intensities, by Commercial Building Type**

<u>Building Types</u>	<u>Percent of Total Lighted Floorspace</u>	<u>Percent of Total Annual Lighting Energy</u>	<u>Annual Lighting End-Use Intensity per Total Lighted Floorspace (kWh/ft<sup>2</sup>)</u>
Education	13.6%	10.1%	4.6
Food Sales	1.1%	1.8%	9.9
Food Service	2.4%	4.2%	10.8
Health Care	4.1%	7.7%	11.5
Lodging	6.4%	7.0%	6.8
Mercantile and Service	22.4%	24.8%	6.9
Office	18.6%	24.5%	8.2
Public Assembly	7.0%	7.2%	6.4
Public Order and Safety	2.3%	1.7%	4.8
Warehouse and Storage	14.0%	6.9%	2.9
Other	1.8%	2.2%	7.8
Vacant	6.2%	1.9%	1.3
	<u>100%</u>	<u>100%</u>	

Note(s): Total lighted floorspace in 1995 was 56.3 billion square feet. Total lighted floorspace for 1999 was 67.3 billion square feet.

Source(s): EIA, A Look at Commercial Buildings in 1995: Characteristics, Energy Consumption, and Energy Expenditures, Oct. 1998, Table BC-40, p. 187, Table EU-1, p. 306-310, and Table EU-2, p. 311-315.